



EVPU[®]

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0163
of February 9, 2010

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Analog Addressable Fire Detection Panel AM-2000

AM-2000 is a microprocessor based analog control panel for fire alarm systems management, developed in compliance with EN 54-2,4 regulations. This control panel has 2 analog loops that can manage 99 detectors and 99 modules each, for a total of 198 detectors and 198 i/o modules. The control panel is also programmable through PK2000 pc software, that allows configuration

placed on the market by

Notifier Italia S.r.l.

Via Grandi, 22 - 20097 San Donato Milanese (MI), Italy

and produced in the factory

VAT Nr. IT 00942050287

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPU a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-2: 1997/A1: 2006/AC: 1999, EN 54-4: 1997/A2: 2006/AC: 1999
were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on February 9, 2010 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Ing. Karol G l a m o š



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.



032089

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk