

# Declaration of Performance

**Nº:1-2-045**

1.- Unique identification code of the product type:

***RP1r-Supra***

***Control and indicating Equipment.***

***Electrical Automatic Control and Delay Device, Environmental Class A***

2.- Contact address of manufacturer

**VAT=B-81838047**

**Laureà Miró nº:401 nave:7**

**08980 St Feliu de Llobregat (Barcelona)**

**España**

3.- Intended use:

***Fixed fire fighting system, Fire Detection and Fire alarm Systems.***

***Components for gas extinguishing systems.***

4.- System of assessment and verification of constancy of performance:

***System 1***

5.- The notified body:

***ANPI 1134***

***Initial inspection of the manufacturing plant***

***EC Certificate of Conformity 1134-CPD-0045 18-9-2012***


6.- Declared performance:

<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonised Technical specification</b>
		<b>EN 12094-1:2003</b>
Trigger delay (response time)	Pass	4.8
Operational reliability	Pass	4,5,6
Constancy of performance in the event of fire	Pass	4.3, 4.4, 4.5, 4.6
Durability	Pass	9

Essential characteristics	Performance	Harmonised Technical specification	
		EN 54-2:1997/A1:2006	EN 54-4:1997/A1:2002+A2:2006
Performance under fire conditions	Pass	4,5,7	
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12	
Operational reliability	Pass	4,5,6,7,8,9,10,11,12,13,14	
Constancy of operational reliability: Temperature resistance	Pass	15.4	9.5
Constancy of operational reliability: Vibration resistance	Pass	15.6, 15.7, 15.15	9.7, 9.8, 9.15
Constancy of operational reliability: Humidity resistance	Pass	15.5, 15.14	9.6, 9.14
Constancy of operational reliability: Electrical stability	Pass	15.8 a 15.13	9.9 a 9.13
Performance of power supply	Pass		4,5,6
Operational reliability	Pass		4,5,6,7,8

- The performance of the product identified in points 1 is in conformity with the declared performance in point 6.
- This declaration of performance is issued under the sole responsibility of manufacturer identified in point 2.
- Name and function:

Jordi Isern  
Manager



St Feliu de Llobregat, 1 of July of 2013